

ATTESTATION OF CONFORMITY



Issued to: Afore New Energy Technology (Shanghai) Co., Ltd.
Build No.7, 333 Wanfang Road, Minhang District, Shanghai, China

For the product: On-Grid PV Inverter

Trade name: 

Type/Model: BNT012KTL, BNT013KTL, BNT015KTL,
BNT017KTL, BNT020KTL, BNT025KTL

Ratings: See Annex

Manufactured by: Afore New Energy Technology (Shanghai) Co., Ltd.
Build No.7, 333 Wanfang Road, Minhang District, Shanghai, China

Requirements: Engineering Recommendation G99 Issue 1 – Amendment 9: 2022

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6136782.53

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 8 June 2023

Number: 6136782.04AOC

DEKRA Testing and Certification (Shanghai) Ltd.


Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

Page 1 of 15

DEKRA Testing and Certification (Shanghai) Ltd.
3F #250 Jiangchangsan Road Shibe Hi-Tech Park, 200436 Jing'an District, Shanghai, China
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-product-safety.com

Annex to 6136782.04AOC

Ratings of the test product:

Operating temperature range: - 25°C to + 60°C

Protective class: I

Ingress protection rating: IP65

Power factor range (adjustable): 0.8 leading...0.8 lagging

BNT012KTL:

PV input: Max. 1100 Vdc, MPPT voltage range: 150-1000 Vdc, max 15*2 A, Isc PV: 25*2 A

AC Output: 3P+N+PE/ 3P+PE, 230/ 400 Vac, 50/ 60 Hz, Nominal 12000 VA, rated 17.4 A, max 21.5 A

BNT013KTL:

PV input: Max. 1100 Vdc, MPPT voltage range: 150-1000 Vdc, max 15*2 A, Isc PV: 25*2 A

AC Output: 3P+N+PE/ 3P+PE, 230/ 400 Vac, 50/ 60 Hz, Nominal 13000 VA, rated 18.9 A, max 22.0 A

BNT015KTL:

PV input: Max. 1100 Vdc, MPPT voltage range: 150-1000 Vdc, max 20 A + 32 A, Isc PV: 30 A + 48 A

AC Output: 3P+N+PE/ 3P+PE, 230/ 400 Vac, 50/ 60 Hz, Nominal 15000 VA, rated 21.8 A, max 27.0 A

BNT017KTL:

PV input: Max. 1100 Vdc, MPPT voltage range: 150-1000 Vdc, max 32*2 A, Isc PV: 48*2 A

AC Output: 3P+N+PE/ 3P+PE, 230/ 400 Vac, 50/ 60 Hz, Nominal 17000 VA, rated 24.7 A, max 30.0 A

BNT020KTL:

PV input: Max. 1100 Vdc, MPPT voltage range: 150-1000 Vdc, max 32*2 A, Isc PV: 48*2 A

AC Output: 3P+N+PE/ 3P+PE, 230/ 400 Vac, 50/ 60 Hz, Nominal 20000 VA, rated 29.0 A, max 32.0 A

BNT025KTL:

PV input: Max. 1100 Vdc, MPPT voltage range: 150-1000 Vdc, max 32*2 A, Isc PV: 48*2 A

AC Output: 3P+N+PE/ 3P+PE, 230/ 400 Vac, 50/ 60 Hz, Nominal 25000 VA, rated 36.3 A, max 40.0 A

G99/1-9 A2-3 Compliance Verification Report –Tests for Type A Inverter Connected Power Generating Modules	
Extract form test report number.:	6136782.53

1. Operating Range:				P
<p>Two tests should be carried with the Power Generating Module operating at Registered Capacity and connected to a suitable test supply or grid simulation set. The power supplied by the primary source shall be kept stable within $\pm 5\%$ of the apparent power value set for the entire duration of each test sequence.</p> <p>Frequency, voltage and Active Power measurements at the output terminals of the Power Generating Module shall be recorded every second. The tests will verify that the Power Generating Module can operate within the required ranges for the specified period of time.</p> <p>The Interface Protection shall be disabled during the tests. In case of a PV Power Park Module the PV primary source may be replaced by a DC source. In case of a full converter Power Park Module (eg wind) the primary source and the prime mover Inverter/rectifier may be replaced by a DC source.</p> <p>Pass or failure of the test should be indicated in the fields below (right hand side), for example with the statement "Pass", "No disconnection occurs", etc. Graphical evidence is preferred. Note that the value of voltage stated in brackets assumes a LV connection. This should be adjusted for HV as required.</p>				
Model: BNT025KTL				
Test 1:				
Measured Voltage (V)	Measured Frequency (Hz)	Measured Power (W)	Measured Power factor	Test Time (seconds)
195.66	47.00	23197.37	0.9995	20
Test 2:				
Measured Voltage (V)	Measured Frequency (Hz)	Measured Power (W)	Measured Power factor	Test Time (Minutes)
195.68	47.50	23209.43	0.9994	90
Test 3:				
Measured Voltage (V)	Measured Frequency (Hz)	Measured Power (W)	Measured Power factor	Test Time (Minutes)
253.22	51.50	25049.54	0.9993	90
Test 4:				
Measured Voltage (V)	Measured Frequency (Hz)	Measured Power (W)	Measured Power factor	Test Time (Minutes)
253.20	52.00	25029.81	0.9992	15
Test 5:				
Measured Voltage (V)	Measured Frequency (Hz)	Measured Power (W)	Measured Power factor	Test Time (Minutes)
230.56	50.00	25063.59	0.9989	90
Test 6:				
Measured Voltage (V)	Ramp range	Test frequency ramp	Test Duration	Confirm no trip
195.5	47.0 Hz to 52.0 Hz	+1 Hzs ⁻¹	5.0s	No trip
253.0	52.0 Hz to 49.0 Hz	-1 Hzs ⁻¹	3.0s	No trip

2. Power Quality – Harmonics:								P	
<p>For Power Generating Modules of Registered Capacity of less than 75 A per phase (ie 50 kW) the test requirements are specified in Annex A.7.1.5. These tests should be carried out as specified in BS EN 61000-3-12, and measurements for the 2nd – 13th harmonics should be provided. The results need to comply with the limits of Table 2 of BS EN 61000-3-12 for single phase equipment and Table 3 of BS EN 61000-3-12 for three phase equipment. For three phase Power Generating Modules, measurements for all phases should be provided.</p> <p>For Power Generating Modules of Registered Capacity of greater than 75 A per phase (ie 50 kW) the installation must be designed in accordance with EREC G5. The rating of the Power Generating Module (per phase) should be provided below, and the Total Harmonic Distortion (THD) and Partial Weighted Harmonic Distortion (PWHD) should be provided at the bottom of this section.</p>									
Model: BNT012KTL									
Power Generating Module tested to BS EN 61000-3-12									
Power Generating Module rating per phase (rpp)				4		kVA		Harmonic % = Measured Value (A) x 23/rating per phase (kVA)	
Single or three phase measurements (for single phase measurements, only complete L1 columns below)				three phase PV inverter					
Harmonic	At 45-55% of Registered Capacity						Limit in BS EN 61000-3-12		
	Measured Value (MV) in Amps			Measured Value (MV) in %					
	L1	L2	L3	L1	L2	L3	1 phase	3 phase	
2	0.144	0.185	0.191	0.827	1.061	1.097	8%	8%	
3	0.025	0.019	0.041	0.145	0.109	0.238	21.6%	Not stated	
4	0.092	0.091	0.096	0.528	0.522	0.555	4%	4%	
5	0.137	0.147	0.149	0.789	0.844	0.858	10.7%	10.7%	
6	0.010	0.010	0.008	0.055	0.058	0.047	2.67%	2.67%	
7	0.102	0.068	0.108	0.585	0.390	0.620	7.2%	7.2%	
8	0.014	0.016	0.015	0.079	0.092	0.085	2%	2%	
9	0.007	0.017	0.018	0.042	0.098	0.101	3.8%	Not stated	
10	0.010	0.011	0.010	0.056	0.063	0.060	1.6%	1.6%	
11	0.029	0.025	0.021	0.168	0.144	0.122	3.1%	3.1%	
12	0.005	0.006	0.006	0.031	0.033	0.032	1.33%	1.33%	
13	0.040	0.012	0.033	0.230	0.071	0.189	2%	2%	
THD	-	-	-	4.140	4.420	4.640	23%	13%	
PWHD	-	-	-	11.187	11.425	11.537	23%	22%	
Harmonic	At 100% of Registered Capacity						Limit in BS EN 61000-3-12		
	Measured Value (MV) in Amps			Measured Value (MV) in %					
	L1	L2	L3	L1	L2	L3	1 phase	3 phase	
2	0.218	0.267	0.292	1.256	1.537	1.680	8%	8%	
3	0.053	0.015	0.078	0.306	0.085	0.447	21.6%	Not stated	
4	0.179	0.163	0.170	1.027	0.937	0.980	4%	4%	
5	0.178	0.209	0.214	1.025	1.202	1.230	10.7%	10.7%	
6	0.009	0.011	0.013	0.050	0.062	0.076	2.67%	2.67%	

Annex to 6136782.04AOC

7	0.180	0.137	0.161	1.034	0.789	0.927	7.2%	7.2%
8	0.051	0.052	0.053	0.291	0.300	0.305	2%	2%
9	0.016	0.011	0.017	0.094	0.062	0.095	3.8%	Not stated
10	0.052	0.060	0.056	0.300	0.342	0.321	1.6%	1.6%
11	0.190	0.188	0.195	1.093	1.083	1.123	3.1%	3.1%
12	0.006	0.006	0.008	0.035	0.033	0.044	1.33%	1.33%
13	0.192	0.162	0.172	1.103	0.933	0.991	2%	2%
THD				3.160	3.210	3.410	23%	13%
PWHD				5.076	5.140	5.210	23%	22%

Model: BNT025KTL								
Power Generating Module tested to BS EN 61000-3-12								
Power Generating Module rating per phase (rpp)				8.33	kVA		Harmonic % = Measured Value (A) x 23/rating per phase (kVA)	
Single or three phase measurements (for single phase measurements, only complete L1 columns below)				three phase PV inverter				
Harmonic	At 45-55% of Registered Capacity						Limit in BS EN 61000-3-12	
	Measured Value (MV) in Amps			Measured Value (MV) in %				
	L1	L2	L3	L1	L2	L3	1 phase	3 phase
2	0.229	0.250	0.235	0.632	0.690	0.649	8%	8%
3	0.046	0.025	0.066	0.127	0.070	0.183	21.6%	Not stated
4	0.155	0.152	0.147	0.428	0.420	0.407	4%	4%
5	0.330	0.335	0.360	0.910	0.925	0.993	10.7%	10.7%
6	0.008	0.010	0.010	0.022	0.028	0.028	2.67%	2.67%
7	0.216	0.218	0.177	0.597	0.602	0.489	7.2%	7.2%
8	0.041	0.042	0.043	0.114	0.115	0.119	2%	2%
9	0.012	0.016	0.018	0.033	0.045	0.049	3.8%	Not stated
10	0.048	0.049	0.047	0.132	0.135	0.130	1.6%	1.6%
11	0.174	0.167	0.174	0.481	0.462	0.482	3.1%	3.1%
12	0.005	0.007	0.007	0.014	0.020	0.019	1.33%	1.33%
13	0.166	0.179	0.138	0.459	0.493	0.381	2%	2%
THD	-	-	-	3.400	3.430	3.450	23%	13%
PWHD	-	-	-	4.681	4.655	4.883	23%	22%
Harmonic	At 100% of Registered Capacity						Limit in BS EN 61000-3-12	
	Measured Value (MV) in Amps			Measured Value (MV) in %				
	L1	L2	L3	L1	L2	L3	1 phase	3 phase
2	0.281	0.337	0.369	0.775	0.931	1.018	8%	8%

Annex to 6136782.04AOC

3	0.070	0.030	0.104	0.193	0.082	0.288	21.6%	Not stated
4	0.233	0.218	0.221	0.643	0.603	0.609	4%	4%
5	0.108	0.165	0.137	0.297	0.456	0.378	10.7%	10.7%
6	0.012	0.012	0.015	0.033	0.034	0.040	2.67%	2.67%
7	0.095	0.160	0.153	0.264	0.442	0.424	7.2%	7.2%
8	0.045	0.042	0.040	0.123	0.117	0.109	2%	2%
9	0.016	0.016	0.039	0.043	0.044	0.108	3.8%	Not stated
10	0.043	0.048	0.050	0.119	0.134	0.139	1.6%	1.6%
11	0.108	0.098	0.101	0.298	0.271	0.280	3.1%	3.1%
12	0.009	0.009	0.008	0.024	0.025	0.023	1.33%	1.33%
13	0.143	0.178	0.119	0.395	0.490	0.328	2%	2%
THD	-	-	-	1.640	1.800	1.850	23%	13%
PWHD	-	-	-	3.683	3.632	3.786	23%	22%

THD = Total Harmonic Distortion

PWHD = Partial Weighted Harmonic Distortion

3. Power Quality – Voltage fluctuations and Flicker:								P	
<p>For Power Generating Modules of Registered Capacity of less than 75 A per phase (ie 50 kW) these tests should be undertaken in accordance with Annex A.7.1.4.3. Results should be normalised to a standard source impedance, or if this results in figures above the limits set in BS EN 61000-3-11 to a suitable Maximum Impedance.</p> <p>For Power Generating Modules of Registered Capacity of greater than 75 A per phase (ie 50 kW) the installation must be designed in accordance with EREC P28.</p> <p>The standard test impedance is 0.4 Ω for a single phase Power Generating Module (and for a two phase unit in a three phase system) and 0.24 Ω for a three phase Power Generating Module (and for a two phase unit in a split phase system). Please ensure that both test and standard impedance are completed on this form. If the test impedance (or the measured impedance) is different to the standard impedance, it must be normalised to the standard impedance as follows (where the Power Factor of the generation output is 0.98 or above):</p> $d \text{ max normalised value} = (\text{Standard impedance} / \text{Measured impedance}) \times \text{Measured value.}$ <p>Where the Power Factor of the output is under 0.98 then the X to R ratio of the test impedance should be close to that of the standard impedance.</p> <p>The stopping test should be a trip from full load operation.</p> <p>The duration of these tests needs to comply with the particular requirements set out in the testing notes for the technology under test. The test date and location must be declared.</p>									
Test start date		2022-07-06			Test end date		2022-07-06		
Test location		No.99, Hongye Road, Suzhou Industrial Park, Suzhou, Jiangsu, P.R. China							
Model:		BNT025KTL							
L1									
Starting			Stopping				Running		
d(max)		d(c)	d(t)	d(max)	d(c)	d(t)	P _{st}	P _{It}	

Annex to 6136782.04AOC

								2 hours
Measured Values at test impedance	0.73	0.05	0	0.84	0.05	0	0.45	0.39
Normalised to standard impedance	0.73	0.05	0	0.84	0.05	0	0.45	0.39
Normalised to required maximum impedance	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Limits set under BS EN 61000-3-11	4%	3.3%	3.3%	4%	3.3%	3.3%	1.0	0.65
Test Impedance	R	0.24	Ω	XI	0.15	Ω		
Standard Impedance	R	0.24 * 0.4 ^	Ω	XI	0.15 * 0.25 ^	Ω		
Maximum Impedance	R	N/A #	Ω	XI	N/A #	Ω		
* Applies to three phase and split single phase Power Generating Modules . ^ Applies to single phase Power Generating Module and Power Generating Modules using two phases on a three phase system. Delete as appropriate.								

Model:	BNT025KTL							
L2								
	Starting			Stopping			Running	
	d(max)	d(c)	d(t)	d(max)	d(c)	d(t)	P _{st}	P _{It} 2 hours
Measured Values at test impedance	0.75	0.04	0	0.81	0.05	0	0.43	0.38
Normalised to standard impedance	0.75	0.04	0	0.81	0.05	0	0.43	0.38
Normalised to required maximum impedance	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Limits set under BS EN 61000-3-11	4%	3.3%	3.3%	4%	3.3%	3.3%	1.0	0.65
Test Impedance	R	0.24	Ω	XI	0.15	Ω		
Standard Impedance	R	0.24 * 0.4 ^	Ω	XI	0.15 * 0.25 ^	Ω		
Maximum Impedance	R	N/A #	Ω	XI	N/A #	Ω		
* Applies to three phase and split single phase Power Generating Modules . ^ Applies to single phase Power Generating Module and Power Generating Modules using two phases on a three phase system. Delete as appropriate.								

Annex to 6136782.04AOC

Model:	BNT025KTL							
L3								
	Starting			Stopping			Running	
	d(max)	d(c)	d(t)	d(max)	d(c)	d(t)	P _{st}	P _{It} 2 hours
Measured Values at test impedance	0.61	0.06	0	0.80	0.06	0	0.48	0.44
Normalised to standard impedance	0.61	0.06	0	0.80	0.06	0	0.48	0.44
Normalised to required maximum impedance	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Limits set under BS EN 61000-3-11	4%	3.3%	3.3%	4%	3.3%	3.3%	1.0	0.65
Test Impedance	R	0.24	Ω	XI	0.15	Ω		
Standard Impedance	R	0.24 * 0.4 ^	Ω	XI	0.15 * 0.25 ^	Ω		
Maximum Impedance	R	N/A #	Ω	XI	N/A #	Ω		
* Applies to three phase and split single phase Power Generating Modules .								
^ Applies to single phase Power Generating Module and Power Generating Modules using two phases on a three phase system. Delete as appropriate.								

4. Power quality – DC injection:				P	
<p>The tests should be carried out on a single Generating Unit. Tests are to be carried out at three defined power levels ±5%. At 230 V a 50 kW three phase Inverter has a current output of 217 A so DC limit is 543 mA. These tests should be undertaken in accordance with Annex A.7.1.4.4.</p> <p>The % DC injection (“as % of rated AC current” below) is calculated as follows:</p> <p>% DC injection = Recorded DC value in Amps / Base current</p> <p>where the base current is the Registered Capacity (W) / Vphase. The % DC injection should not be greater than 0.25%.</p>					
Model: BNT012KTL					
L1					
Test power level	10%		55%		100%
Recorded DC injection value in Amps	-0.022		-0.024		-0.024
as % of rated AC current	-0.04%		-0.05%		-0.05%
Limit	0.25%		0.25%		0.25%
L2					
Test power level	10%		55%		100%
Recorded DC injection value in Amps	-0.029		-0.033		-0.032

Annex to 6136782.04AOC

as % of rated AC current	-0.06%	-0.06%	-0.06%
Limit	0.25%	0.25%	0.25%
L3			
Test power level	10%	55%	100%
Recorded DC injection value in Amps	-0.021	-0.027	-0.026
as % of rated AC current	-0.04%	-0.05%	-0.05%
Limit	0.25%	0.25%	0.25%

Model: BNT025KTL			
L1			
Test power level	10%	55%	100%
Recorded DC injection value in Amps	0.020	0.030	-0.040
as % of rated AC current	0.02%	0.03%	-0.04%
Limit	0.25%	0.25%	0.25%
L2			
Test power level	10%	55%	100%
Recorded DC injection value in Amps	-0.010	-0.030	-0.050
as % of rated AC current	-0.01%	-0.03%	-0.05%
Limit	0.25%	0.25%	0.25%
L3			
Test power level	10%	55%	100%
Recorded DC injection value in Amps	0.010	-0.030	-0.040
as % of rated AC current	0.01%	-0.03%	-0.04%
Limit	0.25%	0.25%	0.25%

Annex to 6136782.04AOC

5. Power Factor:				P
<p>The tests should be carried out on a single Power Generating Module. Tests are to be carried out at three voltage levels and at Registered Capacity and the measured Power Factor must be greater than 0.95 to pass. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test. These tests should be undertaken in accordance with Annex A.7.1.4.2</p> <p>Note that the value of voltage stated in brackets assumes a LV connection. This should be adjusted for HV as required.</p>				
Model: BNT012KTL				
Voltage	0.94 pu (216.2 V)	1 pu (230 V)	1.1 pu (253 V)	
Measured value	0.9998	0.9998	0.9998	
Power Factor Limit	>0.95	>0.95	>0.95	
Model: BNT025KTL				
Voltage	0.94 pu (216.2 V)	1 pu (230 V)	1.1 pu (253 V)	
Measured value	0.9999	0.9999	0.9999	
Power Factor Limit	>0.95	>0.95	>0.95	

6. Protection – Frequency tests:						P
<p>These tests should be carried out in accordance with the Annex A.7.1.2.3. For trip tests, frequency and time delay should be stated. For “no trip tests”, “no trip” can be stated.</p>						
Model: BNT025KTL						
Function	Setting		Trip test		“No trip tests”	
	Frequency	Time delay	Frequency	Time delay	Frequency / time	Confirm no trip
U/F stage 1	47.5 Hz	20 s	47.50Hz	20.04s	47.7 Hz 30 s	No trip
U/F stage 2	47.0 Hz	0.5 s	47.00Hz	0.560s	47.2 Hz 19.5 s	No trip
					46.8 Hz 0.45 s	No trip
O/F	52.0 Hz	0.5 s	52.00Hz	0.557s	51.8 Hz 120.0 s	No trip
					52.2 Hz 0.45 s	No trip
<p>Note: For frequency trip tests the frequency required to trip is the setting ± 0.1 Hz. In order to measure the time delay a larger deviation than the minimum required to operate the projection can be used. The “No trip tests” need to be carried out at the setting ± 0.2 Hz and for the relevant times as shown in the table above to ensure that the protection will not trip in error.</p>						

Annex to 6136782.04AOC

7. Protection – Voltage tests:						P
These tests should be carried out in accordance with Annex A.7.1.2.2. For trip tests, voltage and time delay should be stated. For “no trip tests”, “no trip” can be stated. Note that the value of voltage stated below assumes a LV connection This should be adjusted for HV taking account of the VT ratio as required.						
Model: BNT025KTL						
L1						
Function	Setting		Trip test		“No trip tests”	
	Voltage	Time delay	Voltage	Time delay	Voltage / time	Confirm no trip
U/V	0.8 pu (184 V)	2.5 s	183.4V	2.565s	188 V 5.0 s	No trip
					180 V 2.45 s	No trip
O/V stage 1	1.14 pu (262.2 V)	1.0 s	263.1V	1.036s	258.2 V 5.0 s	No trip
O/V stage 2	1.19 pu (273.7 V)	0.5 s	274.6V	0.548s	269.7 V 0.95 s	No trip
					277.7 V 0.45 s	No trip
Note: For Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.						

7. Protection – Voltage tests:						P
These tests should be carried out in accordance with Annex A.7.1.2.2. For trip tests, voltage and time delay should be stated. For “no trip tests”, “no trip” can be stated. Note that the value of voltage stated below assumes a LV connection This should be adjusted for HV taking account of the VT ratio as required.						
Model: BNT025KTL						
L2						
Function	Setting		Trip test		“No trip tests”	
	Voltage	Time delay	Voltage	Time delay	Voltage / time	Confirm no trip
U/V	0.8 pu (184 V)	2.5 s	182.5V	2.555s	188 V 5.0 s	No trip
					180 V 2.45 s	No trip
O/V stage 1	1.14 pu (262.2 V)	1.0 s	263.4V	1.042s	258.2 V 5.0 s	No trip
O/V stage 2	1.19 pu (273.7 V)	0.5 s	273.9V	0.546s	269.7 V 0.95 s	No trip
					277.7 V 0.45 s	No trip
Note: For Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.						

Annex to 6136782.04AOC

7. Protection – Voltage tests:						P
<p>These tests should be carried out in accordance with Annex A.7.1.2.2. For trip tests, voltage and time delay should be stated. For “no trip tests”, “no trip” can be stated. Note that the value of voltage stated below assumes a LV connection This should be adjusted for HV taking account of the VT ratio as required.</p>						
Model: BNT025KTL						
L3						
Function	Setting		Trip test		“No trip tests”	
	Voltage	Time delay	Voltage	Time delay	Voltage / time	Confirm no trip
U/V	0.8 pu (184 V)	2.5 s	183.3V	2.564s	188 V 5.0 s	No trip
					180 V 2.45 s	No trip
O/V stage 1	1.14 pu (262.2 V)	1.0 s	263.8V	1.062s	258.2 V 5.0 s	No trip
O/V stage 2	1.19 pu (273.7 V)	0.5 s	275.3V	0.522s	269.7 V 0.95 s	No trip
					277.7 V 0.45 s	No trip
<p>Note: For Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.</p>						

8. Protection – Loss of Mains test:						P
<p>These tests should be carried out in accordance with BS EN 62116. Annex A.7.1.2.4. For test condition A, EUT output = 100 % P_n, test condition B, EUT output = 50 % to 66 % P_n, and test condition C, EUT output = 25 % to 33 % P_n.</p>						
Model: BNT025KTL						
The following sub set of tests should be recorded in the following table.						
Test Power and imbalance	33% -5% Q Test 22	66% -5% Q Test 12	100% -5% P Test 5	33% +5% Q Test 31	66% +5% Q Test 21	100% +5% P Test 10
Trip time. Limit is 0.5s	0.103s	0.209s	0.225s	0.115s	0.214s	0.265s

8. Loss of Mains Protection, Vector Shift Stability test:				P
This test should be carried out in accordance with Annex A.7.1.2.6. Confirmation is required that the Power Generating Module does not trip under positive / negative vector shift.				
Model: BNT025KTL				
	Start Frequency	Change	Confirm no trip	
Positive Vector Shift	49.5 Hz	+50 degrees	No trip	
Negative Vector Shift	50.5 Hz	- 50 degrees	No trip	
8. Loss of Mains Protection, RoCoF Stability test:				P
This test should be carried out in accordance with Annex A.7.1.2.6. Confirmation is required that the Power Generating Module does not trip for the duration of the ramp up and ramp down test.				
Model: BNT025KTL				
Ramp range	Test frequency ramp:	Test Duration	Confirm no trip	
49.0 Hz to 51.0 Hz	+0.95 Hzs ⁻¹	2.1 s	No trip	
51.0 Hz to 49.0 Hz	-0.95 Hzs ⁻¹	2.1 s	No trip	

9. Limited Frequency Sensitive Mode – Over frequency test:						P
The test should be carried out using the specific threshold frequency of 50.4 Hz and Droop of 10%. This test should be carried out in accordance with A.7.1.3, which also contains the measurement tolerances.						
Active Power response to rising frequency/time plots are attached if frequency injection tests are undertaken in accordance with Annex A.7.2.4						N
Model: BNT025KTL						
Alternatively, simulation results should be noted below:						
Test sequence at Registered Capacity >80%	Measured Active Power Output (W)	Frequency (Hz)	Calculated droop (%)	Primary Power Source	Active Power Gradient	
Step a) 50.00 Hz ±0.01 Hz	25005.38	50.00	-	Photovoltaic array simulator	-	
Step b) 50.45 Hz ±0.05 Hz	24738.03	50.45	9.34		-	
Step c) 50.70 Hz ±0.10 Hz	23413.33	50.70	9.42		-	
Step d) 51.15 Hz ±0.05 Hz	21233.83	51.15	9.94		-	
Step e) 50.70 Hz ±0.10 Hz	23469.86	50.70	9.77		-	
Step f) 50.45 Hz ±0.05 Hz	24735.59	50.45	9.25		-	
Step g) 50.00 Hz ±0.01 Hz	25003.14	50.00	-		-	
Test sequence at Registered Capacity 40-60%	Measured Active Power Output (W)	Frequency (Hz)	Calculated droop (%)	Primary Power Source	Active Power Gradient	
Step a) 50.00 Hz ±0.01 Hz	12505.11	50.00	-	Photovoltaic array simulator	-	
Step b) 50.45 Hz ±0.05 Hz	12237.78	50.45	9.36		-	
Step c) 50.70 Hz ±0.10 Hz	10921.25	50.70	9.47		-	
Step d) 51.15 Hz ±0.05 Hz	8656.50	51.15	9.74		-	
Step e) 50.70 Hz ±0.10 Hz	10900.00	50.70	9.34		-	

Annex to 6136782.04AOC

Step f) 50.45 Hz ± 0.05 Hz	12235.06	50.45	9.26		-
Step g) 50.00 Hz ± 0.01 Hz	12498.90	50.00	-		-

The frequency at each step should be maintained for at least one minute and the Active Power reduction in the form of a gradient determined and assessed for compliance with paragraph 11.2.3. The Droop should be determined from the measurements between 50.4 Hz and 51.15 Hz. The allowed tolerance for the frequency measurement shall be ± 0.05 Hz. The allowed tolerance for Active Power output measurement shall be $\pm 10\%$ of the required change in Active Power.

The resulting overall tolerance range for a nominal 10% Droop is +2.8% and - 1.5%, ie a Droop less than 12.8% and greater than 8.5%.

10. Protection – Re-connection timer					P
Model: BNT025KTL					
Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 10.1. Both the time delay setting and the measured delay should be provided in this form; both should be greater than 20 s to pass. Confirmation should be provided that the Power Generating Module does not reconnect at the voltage and frequency settings below; a statement of “no reconnection” can be made.					
Time delay setting	Measured delay	Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of Table 10.1.			
60 s	60.7 s	At 1.16 pu (266.2 V LV connection, 127.6 V HV connection assuming 110 Vph-ph VT)	At 0.78 pu (180.0 V LV connection, 85.8 V HV connection assuming 110 V ph-ph VT)	At 47.4 Hz	At 52.1 Hz
Confirmation that the Power Generating Module does not re-connect.		No Reconnection	No Reconnection	No Reconnection	No Reconnection
Recover to normal operation range after confirmation of no connection		Yes	Yes	Yes	Yes
Confirmation that the Power Generating Module shall reconnect		Reconnection after 61.4 s	Reconnection after 60.7s	Reconnection after 61.6 s	Reconnection after 61.1s

11. Fault level contribution:			P
These tests shall be carried out in accordance with EREC G99 Annex A.7.1.5. Please complete each entry, even if the contribution to the fault level is zero.			
Model: BNT025KTL			
For Inverter output			
Time after fault	Volts	Amps	
20ms	53.87 V	43.13 A	
100ms	0	0	
250ms	0	0	
500ms	0	0	
Time to trip	14 ms	In seconds	

12. Self-Monitoring solid state switching: No specified test requirements. Refer to Annex A.7.1.6.	
It has been verified that in the event of the solid state switching device failing to disconnect the Power Park Module , the voltage on the output side of the switching device is reduced to a value below 50 volts within 0.5 s.	N/A
13. Wiring functional tests: If required by para 15.2.1.	
Confirm that the relevant test schedule is attached (tests to be undertaken at time of commissioning)	N/A
14. Logic interface (input port).	
Confirm that an input port is provided and can be used to shut down the module.	Yes
Provide high level description of logic interface, e.g. details in 11.1.3.1 such as AC or DC signal (the additional comments box below can be used)	Yes
15. Cyber security	
Confirm that the Power Generating Module has been designed to comply with cyber security requirements, as detailed in 9.1.7.	Yes Manufacturer's declaration provided
Additional comments.	
To short or open pin1 and pin5 of logic interface port (RS485 port) to control the inverter to normal or shutdown active power of output. A logic interface is provided that can be operated by an external switch or contactor. Users can install by themselves. Users install the switch connected to pin1 and pin5 of RS485 port and just need control the switch signal causing the switch to open or short. When the switch is closed, the inverter will operate normally. When the switch is opened, the inverter will cease to export active power within 5 seconds. The signal from the inverter that is being switched is DC (maximum value 3.3V).	